

VERIFICATION OF COMPLIANCE

No.: LVD NBES200500176701HSC-C1


Applicant: ZENET GMBH
Waldstr, 32 60528 Frankfurt am Main, Germany

Manufacturer: Same as applicant

Product Name: Air Cooler

Product Description: Air Cooler

Model No.: ZET-480, ZET-481, ZET-482, ZET-483, ZET-484, ZET-485, ZET-486, ZET-487, ZET-488, ZET-489, ZET-490

Trade Mark: 

Rating: 220 V - 240 V; 50 Hz / 60 Hz; 60 W; T

Protection against Electric Shock: Class II

Additional Information (if any): None

Sufficient samples of the product have been tested and found to be in conformity with

Test Standard: EN 60335-2-80:2003 + A1:2004 + A2:2009
EN 60335-2-98:2003 + A1:2005 + A2:2008
EN 60335-1:2012 + A11:2014 + A13:2017
EN 62233:2008

as shown in the
Test Report Number(s): NBES200500176701

This Verification of Compliance has been granted to the applicant based on the results of tests, performed by Laboratory of SGS-CSTC Standards Technical Services Co., Ltd. on sample of the above-mentioned product in accordance with the provisions of the relevant harmonized standards under the Low Voltage Directive 2014/35/EU. The CE marking as shown below can be affixed, under the responsibility of the manufacturer, after completion of an EC Declaration of Conformity and compliance with all relevant EC Directives. The affixing of the CE marking presumes in addition that the conditions in annexes III and IV of the Directive are fulfilled.



Leo Du 
E&E Safety Lab Manager
SGS-CSTC



Copyright of this verification is owned by SGS-CSTC Standards Technical Services Co., Ltd. and may not be reproduced other than in full and with the prior approval of the General Manager. This verification is subjected to the governance of the General Conditions of Services, printed overleaf.

Member of SGS Group (Société Générale de Surveillance)

EEC-F03/ Rev.1.1/ 2018-09-21

Page 1 of 1